






Certificate No. : T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
 (Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
 ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
 EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,
 Fax : +91 (0265) 2638382
 E-mail : erda@erda.org
 Web : http://www.erda.org



TEST REPORT

Sheet: 1 of 3

NAME AND ADDRESS OF CUSTOMER SUVIK ELECTRONICS PVT. LTD. PLOT NO. 102/A, G.I.D.C.ENGINEERING ESTATE, SECTOR-28, GANDHINAGAR-382028. GUJARAT, INDIA.	TEST REPORT NO. : LIPS/2919 DATE : 08/03/2010	
	CUSTOMER REF. NO.: Nil	DATE 02/03/2010
	DATE OF SAMPLE RECEIPT 02/03/2010	DATE OF TESTING 02/03/2010 to 03/03/2010
	SAMPLE DESCRIPTION ELECTRICAL PANEL Containing : Bus bar, transformer, Variac, Contactors, Fans, MCCB,	
TEST DETAILS 1.0 IP 53 (category 2) tests Enclosure : i) Drg. No.: C-15309 (sheet 1of 1) ii) Photograph No.: 711310/1 Test Witnessed by: Mr.Jignesh K.Mistry of M/s. Suvik Electronics Pvt. Ltd,Gandhinagar.		TEST SPECIFICATION Cl. No. 7.1.11 of IS/IEC : 60947-1-2004
Remarks: Sample conforms to the requirement of IP 53 (category 2) tests as per the standard.		
 Prepared by	 Checked by	 Approved by

- Note:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
 2. This report cannot be reproduced in part under any circumstances.
 3. Publication of this report requires prior permission in writing from Director, ERDA.
 4. Only the tests asked for by the customer have been carried out.

TE 0411468

